

ID: 40

P3 2025-11-20 Fix aircon flow in server room (ID:40)

23/3/26 Status set to COMPLETED. Refer notes.

Active: True Status: COMPLETED Ticket No.:

Purchase Order No.: Flags (1on1, Exch, ITP): 1on1

Email: russell.thomas@cohdawireless.com

cohda-40.txt -

13/1/26

=====

1on1 meeting - Rhys advised office aircon will be fixed/replaced. Asked to keep me in loop as a possibility to get vents swapped in server room.

4/2/26

=====

Spoke with guy from SeasonAir who was onsite. He said he would organise quote for couple hours work.

9/2/26

=====

Replacement ACU lifted onto roof.

10/2/26

=====

1on1 meeting. Rhys advised quote had not been received from SeasonAir yet. However ducting for new ACU still needs to be done. There is also another ACU in the building that needs replacing.

16/2/26

=====

14:22 Rhys forwarded quote 116037 from Seasonair - \$400 + GST. Responded asking if I should raise a PO.

17/2/26

=====

11:19 Email from Rhys to Seasonair asking them to schedule the work.

23/3/26

=====

Aircon tech attended site & swapped the ducts around. Going by the security temp monitor panel in the server room, the temp dropped 4 degrees - Now at 20 degrees.

Closing ticket.

Ticket UPDATED: 2026-03-23 17:05 (TODO.EXE v2026.3.16.1246)